

消防處
牌照及審批總區
香港九龍尖沙咀東部康莊道1號
消防總部大廈5樓



FIRE SERVICES DEPARTMENT
LICENSING AND CERTIFICATION COMMAND
5/F, Fire Services Headquarters Building,
No.1 Hong Chong Road, Tsim Sha Tsui East,
Kowloon, Hong Kong

本處檔號 OUR REF.: (33) in FP L/M 6/15 (V)
個案編號 LIFIPS No.: 1414270
來函檔號 YOUR REF.: -
電子郵件 E-mail : <lcpolice2@hkfsd.gov.hk>
圖文傳真 FAX NO.: (852) 3850 8450
電話 TEL NO.: (852) 3850 8498

16 October 2023

Hong Kong Airconditioning Parts Centre o/b TYS Ltd.
12/F, Manhattan Centre,
8 Kwai Cheong Road, Kwai Chung,
New Territories, Hong Kong

Dear Sir,

Application for Approval of Pressure Receptacles

I refer to my interim reply of 17 August 2023 on the captioned subject.

Your submitted documents have been scrutinized. Approval under Section 145 of the Dangerous Goods (Control) Regulation, Chapter 295G, Laws of Hong Kong is hereby given to the subject pressure receptacles with the following details to be put into use in Hong Kong:

Manufacturer:	Worthington Cylinders Corporation	Gas Details:	R11, R12, R22, R123, R134a, R513a, R514a, R-1233zd, HFO-1234ze
Manufacturing Standard:	DOT-4BW260	Body Material:	Welded Steel
Quantity:	72 pcs	Serial Number:	See Appendix
Water Capacity:	108.4 Litres	Min. Testing Pressure:	36 Bar
Max. Filling Ratio:	N/A	Max. Working Pressure:	17.93 Bar (260 psi)
Valve Model:	RVE6660L, RVE6660V, LS-700F, RN8544NT405	Max. Testing Period:	5 years
Valve Standard:	CGA 660	Remarks:	N/A

Please also be advised that the relevant sections and regulations under the Dangerous Goods Ordinance, Chapter 295, Laws of Hong Kong and its subsidiary legislation relating to the control and use of pressure receptacle shall be adhered to.

Yours faithfully,

(CHIU Kin-ying)

for Director of Fire Services

c.c. B&PVA, Labour Department
[Ref. (32) in LD BPV/H01/011/GC Pt.3]
CKY/ccl