

消 防 處
牌 照 及 審 批 總 區
香 港 九 龍 尖 沙 咀 東 康 莊 道 1 號 5 樓
消 防 總 部 大 廈



FIRE SERVICES DEPARTMENT
LICENSING AND CERTIFICATION COMMAND
5/F, FIRE SERVICES HEADQUARTERS BUILDING,
No.1 Hong Chong Road, Tsim Sha Tsui East,
Kowloon, Hong Kong

本處檔號 OUR REF.: (27) in FP L/M/6/15(III)
個案編號 LIFIPS No.: 751573
來函檔號 YOUR REF.: APC/Worthington/006
電子郵件 E-mail : <lcpolice2@hkfsd.gov.hk>
圖文傳真 FAX NO.: (852) 2367 3631
電 話 TEL NO.: (852) 2733 7605

27 May 2019

Hong Kong Airconditioning Parts Centre o/b TYS Ltd.
Unit B, 1/F., Hang Fat Industrial Building,
550-556 Castle Peak Road, Cheung Sha Wan,
Kowloon, Hong Kong

Dear Sirs,

**Application for Approval of 17.93 Bar (260.0 psi) Welded Steel Cylinders for
R11, R12, R22, R123, R134a, R-514a & R-1233zd
1 pcs. 450 Litres (Serial No.: 74320G)**

I refer to my interim reply of 9 May 2018 on the captioned subject.

Your submitted documents have been scrutinized. The captioned cylinders manufactured by Worthington Cylinders are found designed, manufactured and tested in accordance with the DOT-4BW260 Specifications and the Sherwood YVE445FR valve with inlet thread specification of 1"-11.5 NPT is suitable for the cylinder.

Approval under Regulation 64 of the Dangerous Goods (General) Regulations, Chapter 295B, Laws of Hong Kong is hereby given to the captioned cylinders to be put into use in Hong Kong. Please also be advised that the relevant sections and regulations under the Dangerous Goods Ordinance, Chapter 295, Laws of Hong Kong and its subsidiary legislations relating to the control and use of gas cylinder shall be adhered to.

One set of duly endorsed supporting document is returned herewith. The other set is retained by this Department for record purpose.

Yours faithfully,

(WONG Ka-shun)
for Director of Fire Services

c.c. B&PVA, Labour Department
[Ref. (9) in LD BPV/H01/001/GC Pt.2]

WKS/ykw